

Lead in Drinking Water Sampling Results Report - **FEBRUARY 2019**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
<b>Bright Horizons At The Department Of Energy (36 SAMPLE records)</b>								
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:11 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:11 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:12 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:13 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:17 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:17 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:18 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:19 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Open Area	Thursday, 02-07-2019	6:22 am	Not Detected	In Progress	
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Open Area	Thursday, 02-07-2019	6:23 am	Not Detected	In Progress	
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Kitchen	Thursday, 02-07-2019	6:28 am	Not Detected	Filter Installed	05-15-2019

GOVERNMENT OF THE DISTRICT OF COLUMBIA  
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Kitchen	Thursday, 02-07-2019	6:28 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Kitchen	Thursday, 02-07-2019	6:29 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Kitchen	Thursday, 02-07-2019	6:30 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Kitchen	Thursday, 02-07-2019	6:33 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Kitchen	Thursday, 02-07-2019	6:33 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Kitchen	Thursday, 02-07-2019	6:34 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Kitchen	Thursday, 02-07-2019	6:35 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:41 am	1.24	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:41 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:42 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:43 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:50 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:50 am	Not Detected	Filter Installed	05-15-2019

GOVERNMENT OF THE DISTRICT OF COLUMBIA  
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:51 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	6:52 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Common Area	Thursday, 02-07-2019	6:56 am	Not Detected	In Progress	
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Common Area	Thursday, 02-07-2019	6:57 am	Not Detected	In Progress	
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	7:00 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	7:00 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	7:01 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	7:02 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	7:07 am	4.69	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	7:07 am	8.89	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	7:08 am	Not Detected	Filter Installed	05-15-2019
Bright Horizons At The Department Of Energy	1000 Independence Avenue SW	6	Classroom	Thursday, 02-07-2019	7:09 am	Not Detected	Filter Installed	05-15-2019
<b>Smithsonian Early Enrichment Center (12 SAMPLE records)</b>								
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Kitchen	Tuesday, 02-05-2019	6:37 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA  
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Kitchen	Tuesday, 02-05-2019	6:37 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Kitchen	Tuesday, 02-05-2019	6:38 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Kitchen	Tuesday, 02-05-2019	6:39 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Classroom	Tuesday, 02-05-2019	6:45 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Classroom	Tuesday, 02-05-2019	6:46 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Classroom	Tuesday, 02-05-2019	6:50 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Classroom	Tuesday, 02-05-2019	6:51 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Classroom	Tuesday, 02-05-2019	6:54 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Classroom	Tuesday, 02-05-2019	6:55 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Classroom	Tuesday, 02-05-2019	6:58 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center	1400 Constitution Avenue NW	2	Classroom	Tuesday, 02-05-2019	6:59 am	Not Detected	In Progress	
<b>Smithsonian Early Enrichment Center II-NHN (20 SAMPLE records)</b>								
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	6:42 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	6:42 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	6:43 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	6:44 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA  
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	6:48 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	6:48 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	6:49 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	6:50 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Kitchen	Wednesday, 02-06-2019	6:53 am	Not Detected	Filter Installed	08-30-2019
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Kitchen	Wednesday, 02-06-2019	6:53 am	Not Detected	Filter Installed	08-30-2019
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Kitchen	Wednesday, 02-06-2019	6:54 am	Not Detected	Filter Installed	08-30-2019
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Kitchen	Wednesday, 02-06-2019	6:55 am	Not Detected	Filter Installed	08-30-2019
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Kitchen	Wednesday, 02-06-2019	6:59 am	Not Detected	Filter Installed	08-30-2019
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Kitchen	Wednesday, 02-06-2019	6:59 am	Not Detected	Filter Installed	08-30-2019
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Kitchen	Wednesday, 02-06-2019	7:00 am	Not Detected	Filter Installed	08-30-2019
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Kitchen	Wednesday, 02-06-2019	7:01 am	Not Detected	Filter Installed	08-30-2019
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	7:05 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	7:06 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	7:08 am	Not Detected	In Progress	
Smithsonian Early Enrichment Center II-NHN	1000 Constitution Avenue NW	6	Classroom	Wednesday, 02-06-2019	7:09 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA  
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
<b>The French Maternal School (8 SAMPLE records)</b>								
The French Maternal School	3115 P Street NW	2	Bathroom	Monday, 02-04-2019	8:02 am		In Progress	
The French Maternal School	3115 P Street NW	2	Bathroom	Monday, 02-04-2019	8:02 am		In Progress	
The French Maternal School	3115 P Street NW	2	Bathroom	Monday, 02-04-2019	8:03 am		In Progress	
The French Maternal School	3115 P Street NW	2	Bathroom	Monday, 02-04-2019	8:04 am		In Progress	
The French Maternal School	3115 P Street NW	2	Bathroom	Monday, 02-04-2019	8:07 am		In Progress	
The French Maternal School	3115 P Street NW	2	Bathroom	Monday, 02-04-2019	8:07 am		In Progress	
The French Maternal School	3115 P Street NW	2	Bathroom	Monday, 02-04-2019	8:08 am		In Progress	
The French Maternal School	3115 P Street NW	2	Bathroom	Monday, 02-04-2019	8:09 am		In Progress	
<b>Vision Of Victory Child Development (1 SAMPLE)</b>								
Vision Of Victory Child Development	2498 Alabama Avenue SE	8	Bathroom	Tuesday, 02-05-2019	8:31 am	Not Detected	In Progress	