

Lead in Drinking Water Sampling Results Report - **SEPTEMBER 2024**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Arsema Childcare (8 SAMPLE records)								
Arsema Childcare	5130 New Hampshire Avenue NW	4	Kitchenette	Wednesday, 09-25-2024	5:56 am	<1.00	In Progress	
Arsema Childcare	5130 New Hampshire Avenue NW	4	Kitchenette	Wednesday, 09-25-2024	5:56 am	<1.00	In Progress	
Arsema Childcare	5130 New Hampshire Avenue NW	4	Kitchenette	Wednesday, 09-25-2024	5:57 am	<1.00	In Progress	
Arsema Childcare	5130 New Hampshire Avenue NW	4	Kitchenette	Wednesday, 09-25-2024	5:58 am	<1.00	In Progress	
Arsema Childcare	5130 New Hampshire Avenue NW	4	Bathroom	Wednesday, 09-25-2024	6:01 am	<1.00	In Progress	
Arsema Childcare	5130 New Hampshire Avenue NW	4	Bathroom	Wednesday, 09-25-2024	6:01 am	<1.00	In Progress	
Arsema Childcare	5130 New Hampshire Avenue NW	4	Bathroom	Wednesday, 09-25-2024	6:02 am	<1.00	In Progress	
Arsema Childcare	5130 New Hampshire Avenue NW	4	Bathroom	Wednesday, 09-25-2024	6:03 am	<1.00	In Progress	
Beauvoir Nursery School (10 SAMPLE records)								
Beauvoir Nursery School	3500 Woodley Road NW	3	Bathroom	Tuesday, 09-17-2024	5:46 am	<1.00	In Progress	
Beauvoir Nursery School	3500 Woodley Road NW	3	Bathroom	Tuesday, 09-17-2024	5:47 am	<1.00	In Progress	
Beauvoir Nursery School	3500 Woodley Road NW	3	Kitchen	Tuesday, 09-17-2024	5:31 am	<1.00	In Progress	
Beauvoir Nursery School	3500 Woodley Road NW	3	Kitchen	Tuesday, 09-17-2024	5:31 am	<1.00	In Progress	
Beauvoir Nursery School	3500 Woodley Road NW	3	Kitchen	Tuesday, 09-17-2024	5:32 am	<1.00	In Progress	
Beauvoir Nursery School	3500 Woodley Road NW	3	Kitchen	Tuesday, 09-17-2024	5:33 am	<1.00	In Progress	
Beauvoir Nursery School	3500 Woodley Road NW	3	Kitchenette	Tuesday, 09-17-2024	5:55 am	<1.00	In Progress	
Beauvoir Nursery School	3500 Woodley Road NW	3	Kitchenette	Tuesday, 09-17-2024	5:56 am	<1.00	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Beauvoir Nursery School	3500 Woodley Road NW	3	Hallway	Tuesday, 09-17-2024	5:57 am	<1.00	In Progress	
Beauvoir Nursery School	3500 Woodley Road NW	3	Hallway	Tuesday, 09-17-2024	5:58 am	<1.00	In Progress	
Cedar Tree Academy PCS (6 SAMPLE records)								
Cedar Tree Academy PCS	701 Howard Road SE	8	Kitchen	Thursday, 09-26-2024	6:00 am	<1.00	In Progress	
Cedar Tree Academy PCS	701 Howard Road SE	8	Kitchen	Thursday, 09-26-2024	6:01 am	<1.00	In Progress	
Cedar Tree Academy PCS	701 Howard Road SE	8	Bathroom	Thursday, 09-26-2024	6:17 am	<1.00	In Progress	
Cedar Tree Academy PCS	701 Howard Road SE	8	Bathroom	Thursday, 09-26-2024	6:18 am	<1.00	In Progress	
Cedar Tree Academy PCS	701 Howard Road SE	8	Hallway	Thursday, 09-26-2024	6:06 am	<1.00	In Progress	
Cedar Tree Academy PCS	701 Howard Road SE	8	Hallway	Thursday, 09-26-2024	6:07 am	<1.00	In Progress	
Chevy Chase Presbyterian Church (6 SAMPLE records)								
Chevy Chase Presbyterian Church	1 Chevy Chase Circle NW	3	Kitchen	Wednesday, 09-18-2024	7:33 am	<1.00	Filter Installed	08-22-2023
Chevy Chase Presbyterian Church	1 Chevy Chase Circle NW	3	Kitchen	Wednesday, 09-18-2024	7:34 am	<1.00	Filter Installed	08-22-2023
Chevy Chase Presbyterian Church	1 Chevy Chase Circle NW	3	Hallway	Wednesday, 09-18-2024	7:40 am	<1.00	In Progress	
Chevy Chase Presbyterian Church	1 Chevy Chase Circle NW	3	Hallway	Wednesday, 09-18-2024	7:41 am	<1.00	In Progress	
Chevy Chase Presbyterian Church	1 Chevy Chase Circle NW	3	Hallway	Wednesday, 09-18-2024	7:45 am	<1.00	In Progress	
Chevy Chase Presbyterian Church	1 Chevy Chase Circle NW	3	Hallway	Wednesday, 09-18-2024	7:46 am	<1.00	In Progress	
Chevy Chase-Bethesda Community Children Center (10 SAMPLE records)								
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Kitchen	Tuesday, 09-17-2024	7:18 am	<1.00	Filter Installed	08-25-2023
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Kitchen	Tuesday, 09-17-2024	7:19 am	<1.00	Filter Installed	08-25-2023
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Classroom	Tuesday, 09-17-2024	7:07 am	5.34	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Classroom	Tuesday, 09-17-2024	7:07 am	1.59	In Progress	
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Classroom	Tuesday, 09-17-2024	7:08 am	<1.00	In Progress	
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Classroom	Tuesday, 09-17-2024	7:09 am	<1.00	In Progress	
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Classroom	Tuesday, 09-17-2024	7:25 am	<1.00	In Progress	
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Classroom	Tuesday, 09-17-2024	7:25 am	<1.00	In Progress	
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Classroom	Tuesday, 09-17-2024	7:26 am	<1.00	In Progress	
Chevy Chase-Bethesda Community Children Center	5671 Western Avenue NW	3	Classroom	Tuesday, 09-17-2024	7:27 am	<1.00	In Progress	
Cleveland Park Kinderhaus (12 SAMPLE records)								
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Classroom	Wednesday, 09-11-2024	7:30 am	<1.00	In Progress	
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Classroom	Wednesday, 09-11-2024	7:30 am	<1.00	In Progress	
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Classroom	Wednesday, 09-11-2024	7:31 am	<1.00	In Progress	
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Classroom	Wednesday, 09-11-2024	7:32 am	<1.00	In Progress	
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Bathroom	Wednesday, 09-11-2024	7:39 am	<1.00	In Progress	
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Bathroom	Wednesday, 09-11-2024	7:39 am	<1.00	In Progress	
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Bathroom	Wednesday, 09-11-2024	7:40 am	<1.00	In Progress	
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Bathroom	Wednesday, 09-11-2024	7:41 am	<1.00	In Progress	
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Kitchen	Wednesday, 09-11-2024	7:46 am	<1.00	Filter Installed	09-25-2019
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Kitchen	Wednesday, 09-11-2024	7:47 am	<1.00	Filter Installed	09-25-2019
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Corridor	Wednesday, 09-11-2024	7:48 am	<1.00	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Cleveland Park Kinderhaus	3400 Lowell Street NW	3	Corridor	Wednesday, 09-11-2024	7:49 am	<1.00	In Progress	
Communikids Preschoo LLC VI (10 SAMPLE records)								
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Bathroom	Wednesday, 09-04-2024	6:37 am	<1.00	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Bathroom	Wednesday, 09-04-2024	6:38 am	<1.00	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Bathroom	Wednesday, 09-04-2024	6:46 am	<1.00	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Bathroom	Wednesday, 09-04-2024	6:47 am	<1.00	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Bathroom	Wednesday, 09-04-2024	6:49 am	<1.00	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Bathroom	Wednesday, 09-04-2024	6:50 am	<1.00	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Bathroom	Wednesday, 09-04-2024	6:52 am	<1.00	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Bathroom	Wednesday, 09-04-2024	6:53 am	1.86	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Hallway	Wednesday, 09-04-2024	7:32 am	<1.00	In Progress	
Communikids Preschoo LLC VI	3400 Idaho Avenue NW - Ste#100A	3	Hallway	Wednesday, 09-04-2024	7:33 am	<1.00	In Progress	
Communikids Preschool LLC IX (10 SAMPLE records)								
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Classroom	Wednesday, 09-04-2024	7:04 am	<1.00	In Progress	
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Classroom	Wednesday, 09-04-2024	7:04 am	<1.00	In Progress	
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Classroom	Wednesday, 09-04-2024	7:05 am	<1.00	In Progress	
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Classroom	Wednesday, 09-04-2024	7:06 am	<1.00	In Progress	
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Classroom	Wednesday, 09-04-2024	7:10 am	<1.00	In Progress	
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Classroom	Wednesday, 09-04-2024	7:10 am	<1.00	In Progress	
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Classroom	Wednesday, 09-04-2024	7:11 am	<1.00	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Classroom	Wednesday, 09-04-2024	7:12 am	<1.00	In Progress	
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Bathroom	Wednesday, 09-04-2024	7:18 am	1.76	In Progress	
Communikids Preschool LLC IX	3400 Idaho Avenue NW, Suite 200	3	Bathroom	Wednesday, 09-04-2024	7:19 am	<1.00	In Progress	
Communikids Preschool LLC VII (4 SAMPLE records)								
Communikids Preschool LLC VII	3400 Idaho Avenue NW - Ste#100B	3	Kitchen	Wednesday, 09-04-2024	6:45 am	<1.00	In Progress	
Communikids Preschool LLC VII	3400 Idaho Avenue NW - Ste#100B	3	Kitchen	Wednesday, 09-04-2024	6:46 am	<1.00	In Progress	
Communikids Preschool LLC VII	3400 Idaho Avenue NW - Ste#100B	3	Hallway	Wednesday, 09-04-2024	7:51 am	<1.00	In Progress	
Communikids Preschool LLC VII	3400 Idaho Avenue NW - Ste#100B	3	Hallway	Wednesday, 09-04-2024	7:52 am	<1.00	In Progress	
Mario Natanni (6 SAMPLE records)								
Mario Natanni	3120 Warder Street NW	1	Kitchen	Wednesday, 09-25-2024	6:33 am	1.69	In Progress	
Mario Natanni	3120 Warder Street NW	1	Kitchen	Wednesday, 09-25-2024	6:33 am	1.27	In Progress	
Mario Natanni	3120 Warder Street NW	1	Kitchen	Wednesday, 09-25-2024	6:34 am	1.38	In Progress	
Mario Natanni	3120 Warder Street NW	1	Kitchen	Wednesday, 09-25-2024	6:35 am	1.41	In Progress	
Mario Natanni	3120 Warder Street NW	1	Bathroom	Wednesday, 09-25-2024	6:39 am	2.95	In Progress	
Mario Natanni	3120 Warder Street NW	1	Bathroom	Wednesday, 09-25-2024	6:40 am	2.40	In Progress	
Metropolitan Methodist Church Nursery School (8 SAMPLE records)								
Metropolitan Methodist Church Nursery School	3401 Nebraska Avenue NW	3	Hallway	Thursday, 09-19-2024	7:24 am	<1.00	In Progress	
Metropolitan Methodist Church Nursery School	3401 Nebraska Avenue NW	3	Hallway	Thursday, 09-19-2024	7:25 am	<1.00	In Progress	
Metropolitan Methodist Church Nursery School	3401 Nebraska Avenue NW	3	Bathroom	Thursday, 09-19-2024	7:29 am	2.44	In Progress	
Metropolitan Methodist Church Nursery School	3401 Nebraska Avenue NW	3	Bathroom	Thursday, 09-19-2024	7:29 am	2.39	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Metropolitan Methodist Church Nursery School	3401 Nebraska Avenue NW	3	Bathroom	Thursday, 09-19-2024	7:30 am	<1.00	In Progress	
Metropolitan Methodist Church Nursery School	3401 Nebraska Avenue NW	3	Bathroom	Thursday, 09-19-2024	7:31 am	1.09	In Progress	
Metropolitan Methodist Church Nursery School	3401 Nebraska Avenue NW	3	Kitchen	Thursday, 09-19-2024	7:43 am	<1.00	Filter Installed	09-01-2023
Metropolitan Methodist Church Nursery School	3401 Nebraska Avenue NW	3	Kitchen	Thursday, 09-19-2024	7:44 am	<1.00	Filter Installed	09-01-2023
National Child Research Center (4 SAMPLE records)								
National Child Research Center	3209 Highland Place NW	3	Classroom	Thursday, 09-12-2024	7:11 am	<1.00	Filter Installed	10-04-2021
National Child Research Center	3209 Highland Place NW	3	Classroom	Thursday, 09-12-2024	7:12 am	<1.00	Filter Installed	10-04-2021
National Child Research Center	3209 Highland Place NW	3	Classroom	Thursday, 09-12-2024	7:20 am	<1.00	Filter Installed	10-05-2021
National Child Research Center	3209 Highland Place NW	3	Classroom	Thursday, 09-12-2024	7:21 am	<1.00	Filter Installed	10-05-2021
National Presbyterian Child Care Center (6 SAMPLE records)								
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Classroom	Tuesday, 09-24-2024	6:19 am	<1.00	Filter Installed	11-16-2022
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Classroom	Tuesday, 09-24-2024	6:20 am	<1.00	Filter Installed	11-16-2022
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Classroom	Tuesday, 09-24-2024	6:16 am	<1.00	Filter Installed	02-07-2023
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Classroom	Tuesday, 09-24-2024	6:17 am	<1.00	Filter Installed	02-07-2023
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Bathroom	Tuesday, 09-24-2024	6:23 am	<1.00	Filter Installed	11-16-2022
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Bathroom	Tuesday, 09-24-2024	6:24 am	<1.00	Filter Installed	11-16-2022
Palisades Montessori Infant and Toddler Center (10 SAMPLE records)								

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Classroom	Thursday, 09-05-2024	8:06 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Classroom	Thursday, 09-05-2024	8:07 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Kitchenette	Thursday, 09-05-2024	7:53 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Kitchenette	Thursday, 09-05-2024	7:53 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Kitchenette	Thursday, 09-05-2024	7:54 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Kitchenette	Thursday, 09-05-2024	7:55 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Bathroom	Thursday, 09-05-2024	7:58 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Bathroom	Thursday, 09-05-2024	7:58 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Bathroom	Thursday, 09-05-2024	7:59 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Bathroom	Thursday, 09-05-2024	8:00 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center II (8 SAMPLE records)								
Palisades Montessori Infant and Toddler Center II	5110 Macarthur Boulevard NW	3	Kitchenette	Thursday, 09-05-2024	8:31 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center II	5110 Macarthur Boulevard NW	3	Kitchenette	Thursday, 09-05-2024	8:31 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center II	5110 Macarthur Boulevard NW	3	Kitchenette	Thursday, 09-05-2024	8:32 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center II	5110 Macarthur Boulevard NW	3	Kitchenette	Thursday, 09-05-2024	8:33 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center II	5110 Macarthur Boulevard NW	3	Bathroom	Thursday, 09-05-2024	8:24 am	<1.00	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Toddler Center II	Boulevard NW							
Palisades Montessori Infant and Toddler Center II	5110 Macarthur Boulevard NW	3	Bathroom	Thursday, 09-05-2024	8:24 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center II	5110 Macarthur Boulevard NW	3	Bathroom	Thursday, 09-05-2024	8:25 am	<1.00	In Progress	
Palisades Montessori Infant and Toddler Center II	5110 Macarthur Boulevard NW	3	Bathroom	Thursday, 09-05-2024	8:26 am	<1.00	In Progress	
TGS Union Row LLC (16 SAMPLE records)								
TGS Union Row LLC	2121 14th Street NW	1	Classroom	Tuesday, 09-10-2024	6:48 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Classroom	Tuesday, 09-10-2024	6:48 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Classroom	Tuesday, 09-10-2024	6:49 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Classroom	Tuesday, 09-10-2024	6:50 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Classroom	Tuesday, 09-10-2024	6:56 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Classroom	Tuesday, 09-10-2024	6:56 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Classroom	Tuesday, 09-10-2024	6:57 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Classroom	Tuesday, 09-10-2024	6:58 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Bathroom	Tuesday, 09-10-2024	7:05 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Bathroom	Tuesday, 09-10-2024	7:05 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Bathroom	Tuesday, 09-10-2024	7:06 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Bathroom	Tuesday, 09-10-2024	7:07 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Kitchen	Tuesday, 09-10-2024	7:13 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Kitchen	Tuesday, 09-10-2024	7:13 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Kitchen	Tuesday, 09-10-2024	7:14 am	<1.00	In Progress	
TGS Union Row LLC	2121 14th Street NW	1	Kitchen	Tuesday, 09-10-2024	7:15 am	<1.00	In Progress	
The River School, Inc. (6 SAMPLE records)								
The River School, Inc.	4880 MacArthur Boulevard NW	3	Classroom	Thursday, 09-12-2024	6:27 am	<1.00	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
The River School, Inc.	4880 MacArthur Boulevard NW	3	Classroom	Thursday, 09-12-2024	6:27 am	<1.00	In Progress	
The River School, Inc.	4880 MacArthur Boulevard NW	3	Classroom	Thursday, 09-12-2024	6:28 am	<1.00	In Progress	
The River School, Inc.	4880 MacArthur Boulevard NW	3	Classroom	Thursday, 09-12-2024	6:29 am	<1.00	In Progress	
The River School, Inc.	4880 MacArthur Boulevard NW	3	Classroom	Thursday, 09-12-2024	6:37 am	<1.00	In Progress	
The River School, Inc.	4880 MacArthur Boulevard NW	3	Classroom	Thursday, 09-12-2024	6:38 am	<1.00	In Progress	