

Lead in Drinking Water Sampling Results Report - **MAY 2022**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Adeola Oyekola (4 SAMPLE records)								
Adeola Oyekola	866 Yuma Street SE	8	Kitchen	Wednesday, 05-04-2022	6:09 am	Not Detected	Filter Installed	07-26-2022
Adeola Oyekola	866 Yuma Street SE	8	Kitchen	Wednesday, 05-04-2022	6:09 am	Not Detected	Filter Installed	07-26-2022
Adeola Oyekola	866 Yuma Street SE	8	Kitchen	Wednesday, 05-04-2022	6:10 am	Not Detected	Filter Installed	07-26-2022
Adeola Oyekola	866 Yuma Street SE	8	Kitchen	Wednesday, 05-04-2022	6:11 am	Not Detected	Filter Installed	07-26-2022
AlphaBEST Education @ KIPP DC Douglass Campus (4 SAMPLE records)								
AlphaBEST Education @ KIPP DC Douglass Campus	2600 Douglass Road SE	8	Cafeteria	Wednesday, 05-11-2022	6:29 am	Not Detected	Filter Installed	02-07-2020
AlphaBEST Education @ KIPP DC Douglass Campus	2600 Douglass Road SE	8	Cafeteria	Wednesday, 05-11-2022	6:30 am	Not Detected	Filter Installed	02-07-2020
AlphaBEST Education @ KIPP DC Douglass Campus	2600 Douglass Road SE	8	Corridor	Wednesday, 05-11-2022	6:24 am	Not Detected	In Progress	
AlphaBEST Education @ KIPP DC Douglass Campus	2600 Douglass Road SE	8	Corridor	Wednesday, 05-11-2022	6:25 am	Not Detected	In Progress	
AlphaBEST Education @ KIPP DC Wheeler Campus (2 SAMPLE records)								
AlphaBEST Education @ KIPP DC Wheeler Campus	3301 Wheeler Road SE	8	Corridor	Thursday, 05-12-2022	6:20 am	Not Detected	In Progress	
AlphaBEST Education @ KIPP DC Wheeler Campus	3301 Wheeler Road SE	8	Corridor	Thursday, 05-12-2022	6:21 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus (16 SAMPLE records)								
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Kitchenette	Tuesday, 05-03-2022	6:58 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Kitchenette	Tuesday, 05-03-2022	6:58 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Kitchenette	Tuesday, 05-03-2022	6:59 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Kitchenette	Tuesday, 05-03-2022	7:00 am	Not Detected	In Progress	

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:04 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:04 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:05 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:06 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:09 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:09 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:10 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:11 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:17 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:17 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:18 am	Not Detected	In Progress	
Apple Tree Early Learning PCS - Douglas Knoll Campus	2017 Savannah Terrace SE	8	Classroom	Tuesday, 05-03-2022	7:19 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest (16 SAMPLE records)								
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Kitchen	Wednesday, 05-11-2022	7:11 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Kitchen	Wednesday, 05-11-2022	7:12 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Classroom	Wednesday, 05-11-2022	7:18 am	Not Detected	In Progress	

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Classroom	Wednesday, 05-11-2022	7:19 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Classroom	Wednesday, 05-11-2022	7:21 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Classroom	Wednesday, 05-11-2022	7:22 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Corridor	Wednesday, 05-11-2022	7:25 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Corridor	Wednesday, 05-11-2022	7:26 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Corridor	Wednesday, 05-11-2022	7:28 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Corridor	Wednesday, 05-11-2022	7:29 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Corridor	Wednesday, 05-11-2022	7:32 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Corridor	Wednesday, 05-11-2022	7:33 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Classroom	Wednesday, 05-11-2022	7:36 am	5.60	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Classroom	Wednesday, 05-11-2022	7:37 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Classroom	Wednesday, 05-11-2022	7:42 am	Not Detected	In Progress	
Apple Tree Early Learning Public Charter School - Southwest	488 Virginia Avenue SW	6	Classroom	Wednesday, 05-11-2022	7:43 am	Not Detected	In Progress	
Artimitia J. Mitchell (2 SAMPLE records)								
Artimitia J. Mitchell	3341 Dubois Place SE	7	Kitchen	Tuesday, 05-24-2022	5:38 am	Not Detected	Filter Installed	08-13-2019
Artimitia J. Mitchell	3341 Dubois Place SE	7	Kitchen	Tuesday, 05-24-2022	5:39 am	Not Detected	Filter Installed	08-13-2019
Community Educational Research Group, Inc (2 SAMPLE records)								
Community Educational Research Group, Inc	2503 Good Hope Road SE	8	Kitchen	Thursday, 05-05-2022	6:47 am	Not Detected	Filter Installed	05-30-2019

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Community Educational Research Group, Inc	2503 Good Hope Road SE	8	Kitchen	Thursday, 05-05-2022	6:48 am	Not Detected	Filter Installed	05-30-2019
Eagle Academy Public Charter School #1 (6 SAMPLE records)								
Eagle Academy Public Charter School #1	3400 Wheeler Road SE	8	Kitchen	Thursday, 05-12-2022	5:51 am	Not Detected	In Progress	
Eagle Academy Public Charter School #1	3400 Wheeler Road SE	8	Kitchen	Thursday, 05-12-2022	5:51 am	Not Detected	In Progress	
Eagle Academy Public Charter School #1	3400 Wheeler Road SE	8	Kitchen	Thursday, 05-12-2022	5:52 am	Not Detected	In Progress	
Eagle Academy Public Charter School #1	3400 Wheeler Road SE	8	Kitchen	Thursday, 05-12-2022	5:53 am	Not Detected	In Progress	
Eagle Academy Public Charter School #1	3400 Wheeler Road SE	8	Corridor	Thursday, 05-12-2022	5:44 am	Not Detected	In Progress	
Eagle Academy Public Charter School #1	3400 Wheeler Road SE	8	Corridor	Thursday, 05-12-2022	5:45 am	Not Detected	In Progress	
Emergent Preparatory Academy (18 SAMPLE records)								
Emergent Preparatory Academy	2801 Stanton Road SE	8	Kitchen	Wednesday, 05-18-2022	7:24 am	Not Detected	Filter Installed	05-28-2019
Emergent Preparatory Academy	2801 Stanton Road SE	8	Kitchen	Wednesday, 05-18-2022	7:25 am	Not Detected	Filter Installed	05-28-2019
Emergent Preparatory Academy	2801 Stanton Road SE	8	Kitchen	Wednesday, 05-18-2022	7:26 am	Not Detected	Filter Installed	05-28-2019
Emergent Preparatory Academy	2801 Stanton Road SE	8	Kitchen	Wednesday, 05-18-2022	7:27 am	Not Detected	Filter Installed	05-28-2019
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:01 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:01 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:02 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:03 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:05 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:05 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:06 am	Not Detected	In Progress	

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:07 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:10 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:10 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:11 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:12 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:14 am	Not Detected	In Progress	
Emergent Preparatory Academy	2801 Stanton Road SE	8	Bathroom	Wednesday, 05-18-2022	7:15 am	Not Detected	In Progress	
Kiddies Kollege (26 SAMPLE records)								
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Friday, 05-20-2022	7:23 am	1.08	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Friday, 05-20-2022	7:24 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Kitchen	Thursday, 05-12-2022	6:45 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Kitchen	Thursday, 05-12-2022	6:45 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Kitchen	Thursday, 05-12-2022	6:46 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Kitchen	Thursday, 05-12-2022	6:47 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	6:52 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	6:53 am	1.08	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	6:58 am	2.57	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	6:59 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Bathroom	Thursday, 05-12-2022	7:06 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Bathroom	Thursday, 05-12-2022	7:07 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Bathroom	Thursday, 05-12-2022	7:16 am	2.39	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Bathroom	Thursday, 05-12-2022	7:17 am	2.85	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:21 am	2.21	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:22 am	Not Detected	In Progress	

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:28 am	1.13	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:29 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:35 am	8.88	Filter Installed	07-26-2022
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:36 am	1.02	Filter Installed	07-26-2022
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:42 am	5.83	Filter Installed	07-26-2022
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:43 am	Not Detected	Filter Installed	07-26-2022
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:53 am	1.69	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Classroom	Thursday, 05-12-2022	7:54 am	Not Detected	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Bathroom	Thursday, 05-12-2022	7:56 am	1.11	In Progress	
Kiddies Kollege	1130 Varney Street SE	8	Bathroom	Thursday, 05-12-2022	7:57 am	Not Detected	In Progress	
Kids Are People Too CDC II (18 SAMPLE records)								
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:18 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:18 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:19 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:20 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:25 am	2.29	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:26 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:28 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:28 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:29 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:30 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:34 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:34 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:35 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:36 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:41 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:41 am	Not Detected	In Progress	

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:42 am	Not Detected	In Progress	
Kids Are People Too CDC II	408 61st Street NE	7	Bathroom	Thursday, 05-19-2022	7:43 am	Not Detected	In Progress	
Kids Are People Too CDC V (2 SAMPLE records)								
Kids Are People Too CDC V	4315 Nannie Helen Burroughs Avenue NE	7	Kitchen	Thursday, 05-19-2022	5:59 am	Not Detected	Filter Installed	08-16-2019
Kids Are People Too CDC V	4315 Nannie Helen Burroughs Avenue NE	7	Kitchen	Thursday, 05-19-2022	6:00 am	Not Detected	Filter Installed	08-16-2019
Kuumba Learning Center (4 SAMPLE records)								
Kuumba Learning Center	3328 Martin Luther King Jr. Avenue SE	8	Kitchen	Tuesday, 05-10-2022	8:18 am	Not Detected	In Progress	
Kuumba Learning Center	3328 Martin Luther King Jr. Avenue SE	8	Kitchen	Tuesday, 05-10-2022	8:18 am	Not Detected	In Progress	
Kuumba Learning Center	3328 Martin Luther King Jr. Avenue SE	8	Kitchen	Tuesday, 05-10-2022	8:19 am	Not Detected	In Progress	
Kuumba Learning Center	3328 Martin Luther King Jr. Avenue SE	8	Kitchen	Tuesday, 05-10-2022	8:20 am	Not Detected	In Progress	
Lakeisha Cameron/Blessing CDH (4 SAMPLE records)								
Lakeisha Cameron/Blessing CDH	3249 Stanton Road SE	8	Kitchen	Tuesday, 05-03-2022	8:05 am	Not Detected	Filter Installed	08-07-2019
Lakeisha Cameron/Blessing CDH	3249 Stanton Road SE	8	Kitchen	Tuesday, 05-03-2022	8:05 am	Not Detected	Filter Installed	08-07-2019
Lakeisha Cameron/Blessing CDH	3249 Stanton Road SE	8	Kitchen	Tuesday, 05-03-2022	8:06 am	Not Detected	Filter Installed	08-07-2019
Lakeisha Cameron/Blessing CDH	3249 Stanton Road SE	8	Kitchen	Tuesday, 05-03-2022	8:07 am	Not Detected	Filter Installed	08-07-2019
Linda T Waller (2 SAMPLE records)								
Linda T Waller	130 Elmira Street SW	8	Kitchen	Wednesday, 05-04-2022	6:45 am	Not Detected	Filter Installed	08-08-2019
Linda T Waller	130 Elmira Street SW	8	Kitchen	Wednesday, 05-04-2022	6:46 am	Not Detected	Filter Installed	08-08-2019
New Creation Child Development Center (2 SAMPLE records)								
New Creation Child Development Center	1839 Alabama Avenue SE	8	Kitchen	Wednesday, 05-11-2022	6:40 am	Not Detected	Filter Installed	06-13-2019
New Creation Child Development Center	1839 Alabama Avenue SE	8	Kitchen	Wednesday, 05-11-2022	6:41 am	Not Detected	Filter Installed	06-13-2019
Priscilla Collins/Runn & Shoot With Me (10 SAMPLE records)								

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Kitchen	Wednesday, 05-18-2022	6:40 am	Not Detected	Filter Installed	07-02-2019
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Kitchen	Wednesday, 05-18-2022	6:40 am	Not Detected	Filter Installed	07-02-2019
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Kitchen	Wednesday, 05-18-2022	6:41 am	Not Detected	Filter Installed	07-02-2019
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Kitchen	Wednesday, 05-18-2022	6:42 am	Not Detected	Filter Installed	07-02-2019
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Kitchenette	Wednesday, 05-18-2022	6:31 am	Not Detected	Filter Installed	07-26-2022
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Kitchenette	Wednesday, 05-18-2022	6:31 am	Not Detected	Filter Installed	07-26-2022
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Kitchenette	Wednesday, 05-18-2022	6:32 am	1.67	Filter Installed	07-26-2022
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Kitchenette	Wednesday, 05-18-2022	6:33 am	Not Detected	Filter Installed	07-26-2022
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Bathroom	Wednesday, 05-18-2022	6:36 am	Not Detected	Filter Installed	10-04-2019
Priscilla Collins/Runn & Shoot With Me	1432 Bangor Street SE	8	Bathroom	Wednesday, 05-18-2022	6:37 am	Not Detected	Filter Installed	10-04-2019
Renita Hill/Angels Arena Child Care (8 SAMPLE records)								
Renita Hill/Angels Arena Child Care	1425 Bangor Street SE	8	Kitchen	Thursday, 05-05-2022	6:10 am	Not Detected	Filter Installed	07-25-2022
Renita Hill/Angels Arena Child Care	1425 Bangor Street SE	8	Kitchen	Thursday, 05-05-2022	6:10 am	Not Detected	Filter Installed	07-25-2022
Renita Hill/Angels Arena Child Care	1425 Bangor Street SE	8	Kitchen	Thursday, 05-05-2022	6:11 am	Not Detected	Filter Installed	07-25-2022
Renita Hill/Angels Arena Child Care	1425 Bangor Street SE	8	Kitchen	Thursday, 05-05-2022	6:12 am	Not Detected	Filter Installed	07-25-2022
Renita Hill/Angels Arena Child Care	1425 Bangor Street SE	8	Bathroom	Thursday, 05-05-2022	6:17 am	Not Detected	Filter Installed	07-25-2022
Renita Hill/Angels Arena Child Care	1425 Bangor Street SE	8	Bathroom	Thursday, 05-05-2022	6:17 am	Not Detected	Filter Installed	07-25-2022
Renita Hill/Angels Arena Child Care	1425 Bangor Street SE	8	Bathroom	Thursday, 05-05-2022	6:18 am	Not Detected	Filter Installed	07-25-2022
Renita Hill/Angels Arena Child Care	1425 Bangor Street SE	8	Bathroom	Thursday, 05-05-2022	6:19 am	Not Detected	Filter Installed	07-25-2022
Rocketship Rise Academy (16 SAMPLE records)								
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:22 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:22 am	Not Detected	In Progress	

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:23 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:24 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:11 am	2.69	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:11 am	1.06	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:12 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:13 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:15 am	3.38	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:15 am	1.15	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:16 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Kitchen	Thursday, 05-05-2022	6:17 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Classroom	Thursday, 05-05-2022	6:29 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Classroom	Thursday, 05-05-2022	6:29 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Classroom	Thursday, 05-05-2022	6:30 am	Not Detected	In Progress	
Rocketship Rise Academy	2335 Raynolds Place SE	8	Classroom	Thursday, 05-05-2022	6:31 am	Not Detected	In Progress	
St. Philip's Child Development Center (28 SAMPLE records)								
St. Philip's Child Development Center	2001 14th Street SE	8	Kitchen	Tuesday, 05-03-2022	6:40 am	Not Detected	Filter Installed	06-19-2019
St. Philip's Child Development Center	2001 14th Street SE	8	Kitchen	Tuesday, 05-03-2022	6:40 am	Not Detected	Filter Installed	06-19-2019
St. Philip's Child Development Center	2001 14th Street SE	8	Kitchen	Tuesday, 05-03-2022	6:41 am	Not Detected	Filter Installed	06-19-2019
St. Philip's Child Development Center	2001 14th Street SE	8	Kitchen	Tuesday, 05-03-2022	6:42 am	Not Detected	Filter Installed	06-19-2019
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	6:48 am	Not Detected	In Progress	

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	6:48 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	6:49 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	6:50 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	6:55 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	6:55 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	6:56 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	6:57 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:00 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:00 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:01 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:02 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:10 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:10 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:11 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:12 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:16 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:16 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:17 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:18 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:22 am	Not Detected	In Progress	

Lead-Safe and Healthy Housing Division

Lead in Drinking Water Filtration Program

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:22 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:23 am	Not Detected	In Progress	
St. Philip's Child Development Center	2001 14th Street SE	8	Bathroom	Tuesday, 05-03-2022	7:24 am	Not Detected	In Progress	
Sylvia Crews/ LTH Infants and Toddlers (8 SAMPLE records)								
Sylvia Crews/ LTH Infants and Toddlers	5036 Queens Stroll Place SE	7	Kitchen	Thursday, 05-26-2022	6:00 am	Not Detected	In Progress	
Sylvia Crews/ LTH Infants and Toddlers	5036 Queens Stroll Place SE	7	Kitchen	Thursday, 05-26-2022	6:00 am	Not Detected	In Progress	
Sylvia Crews/ LTH Infants and Toddlers	5036 Queens Stroll Place SE	7	Kitchen	Thursday, 05-26-2022	6:01 am	Not Detected	In Progress	
Sylvia Crews/ LTH Infants and Toddlers	5036 Queens Stroll Place SE	7	Kitchen	Thursday, 05-26-2022	6:02 am	Not Detected	In Progress	
Sylvia Crews/ LTH Infants and Toddlers	5036 Queens Stroll Place SE	7	Bathroom	Thursday, 05-26-2022	6:10 am	Not Detected	In Progress	
Sylvia Crews/ LTH Infants and Toddlers	5036 Queens Stroll Place SE	7	Bathroom	Thursday, 05-26-2022	6:10 am	Not Detected	In Progress	
Sylvia Crews/ LTH Infants and Toddlers	5036 Queens Stroll Place SE	7	Bathroom	Thursday, 05-26-2022	6:11 am	Not Detected	In Progress	
Sylvia Crews/ LTH Infants and Toddlers	5036 Queens Stroll Place SE	7	Bathroom	Thursday, 05-26-2022	6:12 am	Not Detected	In Progress	
The Elizabeth Ministry/Asa Early Learning Academy (2 SAMPLE records)								
The Elizabeth Ministry/Asa Early Learning Academy	200 55th Street NE	7	Kitchen	Tuesday, 05-24-2022	6:11 am	Not Detected	Filter Installed	08-14-2019
The Elizabeth Ministry/Asa Early Learning Academy	200 55th Street NE	7	Kitchen	Tuesday, 05-24-2022	6:12 am	Not Detected	Filter Installed	08-14-2019
UPO @ Anacostia High School (14 SAMPLE records)								
UPO @ Anacostia High School	1601 16th Street SE	8	Teacher Lounge	Thursday, 05-26-2022	7:24 am	Not Detected	Filter Installed	05-07-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Teacher Lounge	Thursday, 05-26-2022	7:25 am	Not Detected	Filter Installed	05-07-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Kitchen	Thursday, 05-26-2022	7:07 am	Not Detected	Filter Installed	05-02-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Kitchen	Thursday, 05-26-2022	7:08 am	Not Detected	Filter Installed	05-02-2019

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
UPO @ Anacostia High School	1601 16th Street SE	8	Classroom	Thursday, 05-26-2022	7:29 am	Not Detected	Filter Installed	05-02-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Classroom	Thursday, 05-26-2022	7:30 am	Not Detected	Filter Installed	05-02-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Classroom	Thursday, 05-26-2022	7:32 am	Not Detected	Filter Installed	05-02-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Classroom	Thursday, 05-26-2022	7:33 am	Not Detected	Filter Installed	05-02-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Classroom	Thursday, 05-26-2022	7:14 am	Not Detected	Filter Installed	05-02-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Classroom	Thursday, 05-26-2022	7:15 am	Not Detected	Filter Installed	05-02-2019
UPO @ Anacostia High School	1601 16th Street SE	8	Kitchenette	Thursday, 05-26-2022	7:18 am	1.81	In Progress	
UPO @ Anacostia High School	1601 16th Street SE	8	Kitchenette	Thursday, 05-26-2022	7:18 am	Not Detected	In Progress	
UPO @ Anacostia High School	1601 16th Street SE	8	Kitchenette	Thursday, 05-26-2022	7:19 am	Not Detected	In Progress	
UPO @ Anacostia High School	1601 16th Street SE	8	Kitchenette	Thursday, 05-26-2022	7:20 am	Not Detected	In Progress	
UPO @ Paradise Early Childhood Center (6 SAMPLE records)								
UPO @ Paradise Early Childhood Center	3513 Jay Street NE	7	Kitchen	Thursday, 05-19-2022	6:38 am	Not Detected	Filter Installed	08-16-2019
UPO @ Paradise Early Childhood Center	3513 Jay Street NE	7	Kitchen	Thursday, 05-19-2022	6:39 am	Not Detected	Filter Installed	08-16-2019
UPO @ Paradise Early Childhood Center	3513 Jay Street NE	7	Classroom	Thursday, 05-19-2022	6:49 am	Not Detected	In Progress	
UPO @ Paradise Early Childhood Center	3513 Jay Street NE	7	Classroom	Thursday, 05-19-2022	6:49 am	Not Detected	In Progress	
UPO @ Paradise Early Childhood Center	3513 Jay Street NE	7	Classroom	Thursday, 05-19-2022	6:50 am	Not Detected	In Progress	
UPO @ Paradise Early Childhood Center	3513 Jay Street NE	7	Classroom	Thursday, 05-19-2022	6:51 am	Not Detected	In Progress	
Vee's Early Education Center (4 SAMPLE records)								
Vee's Early Education Center	2130 Minnesota Avenue SE	8	Kitchen	Tuesday, 05-10-2022	7:42 am	Not Detected	Filter Installed	05-24-2019
Vee's Early Education Center	2130 Minnesota Avenue SE	8	Kitchen	Tuesday, 05-10-2022	7:43 am	Not Detected	Filter Installed	05-24-2019
Vee's Early Education Center	2130 Minnesota Avenue SE	8	Kitchen	Tuesday, 05-10-2022	7:47 am	Not Detected	Filter Installed	05-24-2019
Vee's Early Education Center	2130 Minnesota Avenue SE	8	Kitchen	Tuesday, 05-10-2022	7:48 am	Not Detected	Filter Installed	05-24-2019
Winifred Thomas (4 SAMPLE records)								

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Winifred Thomas	126 Yuma Street SE	8	Kitchen	Wednesday, 05-04-2022	8:02 am	Not Detected	In Progress	
Winifred Thomas	126 Yuma Street SE	8	Kitchen	Wednesday, 05-04-2022	8:02 am	Not Detected	In Progress	
Winifred Thomas	126 Yuma Street SE	8	Kitchen	Wednesday, 05-04-2022	8:03 am	Not Detected	In Progress	
Winifred Thomas	126 Yuma Street SE	8	Kitchen	Wednesday, 05-04-2022	8:04 am	Not Detected	In Progress	