

Lead in Drinking Water Sampling Results Report - **JUNE 2021**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
2 New Heights Child Development Center (4 SAMPLE records)								
2 New Heights Child Development Center	6207 Blair Road NW	4	Kitchen	Tuesday, 06-29-2021	6:37 am	Not Detected	Filter Installed	12-13-2021
2 New Heights Child Development Center	6207 Blair Road NW	4	Kitchen	Tuesday, 06-29-2021	6:37 am	Not Detected	Filter Installed	12-13-2021
2 New Heights Child Development Center	6207 Blair Road NW	4	Kitchen	Tuesday, 06-29-2021	6:38 am	Not Detected	Filter Installed	12-13-2021
2 New Heights Child Development Center	6207 Blair Road NW	4	Kitchen	Tuesday, 06-29-2021	6:39 am	Not Detected	Filter Installed	12-13-2021
ABC Child Development Center (4 SAMPLE records)								
ABC Child Development Center	32 Grant Circle NW	4	Kitchen	Wednesday, 06-16-2021	7:21 am	Not Detected	Filter Installed	12-13-2021
ABC Child Development Center	32 Grant Circle NW	4	Kitchen	Wednesday, 06-16-2021	7:21 am	Not Detected	Filter Installed	12-13-2021
ABC Child Development Center	32 Grant Circle NW	4	Kitchen	Wednesday, 06-16-2021	7:22 am	Not Detected	Filter Installed	12-13-2021
ABC Child Development Center	32 Grant Circle NW	4	Kitchen	Wednesday, 06-16-2021	7:23 am	Not Detected	Filter Installed	12-13-2021
Bambino Kids Daycare Inc. (4 SAMPLE records)								
Bambino Kids Daycare Inc.	3919 14th Street NW	4	Kitchen	Thursday, 06-24-2021	8:12 am	Not Detected	Filter Installed	12-13-2021
Bambino Kids Daycare Inc.	3919 14th Street NW	4	Kitchen	Thursday, 06-24-2021	8:12 am	Not Detected	Filter Installed	12-13-2021
Bambino Kids Daycare Inc.	3919 14th Street NW	4	Kitchen	Thursday, 06-24-2021	8:13 am	Not Detected	Filter Installed	12-13-2021
Bambino Kids Daycare Inc.	3919 14th Street NW	4	Kitchen	Thursday, 06-24-2021	8:14 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center (20 SAMPLE records)								
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Kitchenette	Wednesday, 06-23-2021	7:04 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Kitchenette	Wednesday, 06-23-2021	7:04 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Kitchenette	Wednesday, 06-23-2021	7:05 am	1.12	Filter Installed	12-13-2021

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Kitchenette	Wednesday, 06-23-2021	7:06 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:10 am	3.28	In Progress	
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:10 am	1.38	In Progress	
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:11 am	Not Detected	In Progress	
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:12 am	1.01	In Progress	
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:15 am	Not Detected	In Progress	
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:15 am	Not Detected	In Progress	
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:16 am	Not Detected	In Progress	
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:17 am	Not Detected	In Progress	
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Kitchenette	Wednesday, 06-23-2021	7:24 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Kitchenette	Wednesday, 06-23-2021	7:24 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Kitchenette	Wednesday, 06-23-2021	7:25 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Kitchenette	Wednesday, 06-23-2021	7:26 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:29 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:29 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:30 am	Not Detected	Filter Installed	12-13-2021
Bellas Artes Child Creativity Center	1613 Rhode Island Avenue NE	5	Bathroom	Wednesday, 06-23-2021	7:31 am	Not Detected	Filter Installed	12-13-2021
Bridges Early Childhood Academy (4 SAMPLE records)								
Bridges Early Childhood Academy	6125 Georgia Avenue NW	4	Kitchen	Tuesday, 06-22-2021	7:13 am	Not Detected	Filter Installed	09-13-2019
Bridges Early Childhood Academy	6125 Georgia Avenue NW	4	Kitchen	Tuesday, 06-22-2021	7:13 am	Not Detected	Filter Installed	09-13-2019

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Bridges Early Childhood Academy	6125 Georgia Avenue NW	4	Kitchen	Tuesday, 06-22-2021	7:14 am	Not Detected	Filter Installed	09-13-2019
Bridges Early Childhood Academy	6125 Georgia Avenue NW	4	Kitchen	Tuesday, 06-22-2021	7:15 am	Not Detected	Filter Installed	09-13-2019
CentroNla @ Cardozo High School (4 SAMPLE records)								
CentroNla @ Cardozo High School	1200 Clifton Street NW	1	Kitchen	Wednesday, 06-16-2021	7:43 am	Not Detected	Filter Installed	10-08-2019
CentroNla @ Cardozo High School	1200 Clifton Street NW	1	Kitchen	Wednesday, 06-16-2021	7:44 am	Not Detected	Filter Installed	10-08-2019
CentroNla @ Cardozo High School	1200 Clifton Street NW	1	Classroom	Wednesday, 06-16-2021	7:47 am	Not Detected	Filter Installed	10-08-2019
CentroNla @ Cardozo High School	1200 Clifton Street NW	1	Classroom	Wednesday, 06-16-2021	7:48 am	Not Detected	Filter Installed	10-08-2019
Curious Explorers Child Development Center (14 SAMPLE records)								
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Kitchen	Tuesday, 06-08-2021	7:41 am	Not Detected	Filter Installed	11-12-2020
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Kitchen	Tuesday, 06-08-2021	7:42 am	Not Detected	Filter Installed	11-12-2020
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	7:45 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	7:45 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	7:46 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	7:47 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	7:49 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	7:49 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	7:50 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	7:51 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Classroom	Tuesday, 06-08-2021	7:53 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Classroom	Tuesday, 06-08-2021	7:53 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Classroom	Tuesday, 06-08-2021	7:54 am	Not Detected	In Progress	
Curious Explorers Child Development Center	5700 Georgia Avenue NW	4	Classroom	Tuesday, 06-08-2021	7:55 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development (32 SAMPLE records)								
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Open Area	Tuesday, 06-08-2021	5:06 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Open Area	Tuesday, 06-08-2021	5:07 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:12 am	16.5	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:12 am	103	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:13 am	4.22	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:14 am	3.26	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:16 am	99.6	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:16 am	63.4	Filter Installed	07-21-2021
David's Stars Child	4813 Georgia	4	Bathroom	Tuesday, 06-08-2021	5:17 am	3.60	Filter Installed	07-21-2021

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Development Center Brains in Development	Avenue NW							
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:18 am	2.05	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchenette	Tuesday, 06-08-2021	5:22 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchenette	Tuesday, 06-08-2021	5:22 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchenette	Tuesday, 06-08-2021	5:23 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchenette	Tuesday, 06-08-2021	5:24 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchenette	Tuesday, 06-08-2021	5:29 am	Not Detected	Filter Installed	07-07-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchenette	Tuesday, 06-08-2021	5:29 am	Not Detected	Filter Installed	07-07-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchenette	Tuesday, 06-08-2021	5:30 am	Not Detected	Filter Installed	07-07-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchenette	Tuesday, 06-08-2021	5:31 am	Not Detected	Filter Installed	07-07-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchen	Tuesday, 06-08-2021	5:35 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchen	Tuesday, 06-08-2021	5:35 am	Not Detected	Filter Installed	07-21-2021

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchen	Tuesday, 06-08-2021	5:36 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Kitchen	Tuesday, 06-08-2021	5:37 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Open Area	Tuesday, 06-08-2021	5:39 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Open Area	Tuesday, 06-08-2021	5:40 am	Not Detected	In Progress	
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:44 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:44 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:45 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:46 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:47 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:47 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains in Development	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:48 am	Not Detected	Filter Installed	07-21-2021
David's Stars Child Development Center Brains	4813 Georgia Avenue NW	4	Bathroom	Tuesday, 06-08-2021	5:49 am	Not Detected	Filter Installed	07-21-2021

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
in Development								
DCJCC Preschool (40 SAMPLE records)								
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:08 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:08 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:09 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:10 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:14 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:14 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:15 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:16 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:19 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:19 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:20 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:21 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:24 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:24 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:25 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:26 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:30 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:30 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:31 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:32 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:36 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:36 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:37 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:38 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:42 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:42 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:43 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:44 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:47 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:47 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:48 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:49 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:53 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:53 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:54 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:55 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:59 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	6:59 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	7:00 am	Not Detected	In Progress	
DCJCC Preschool	1529 16th Street NW	2	Classroom	Wednesday, 06-30-2021	7:01 am	Not Detected	In Progress	
Kidz Care Unlimited Child Development Center (4 SAMPLE records)								
Kidz Care Unlimited Child Development Center	128 M Street NW	6	Kitchen	Thursday, 06-17-2021	6:40 am	Not Detected	In Progress	
Kidz Care Unlimited Child Development Center	128 M Street NW	6	Kitchen	Thursday, 06-17-2021	6:40 am	Not Detected	In Progress	
Kidz Care Unlimited Child Development Center	128 M Street NW	6	Kitchen	Thursday, 06-17-2021	6:41 am	Not Detected	In Progress	
Kidz Care Unlimited Child Development Center	128 M Street NW	6	Kitchen	Thursday, 06-17-2021	6:42 am	Not Detected	In Progress	
KU Kids Deanwood, LLC (10 SAMPLE records)								

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	6:57 am	Not Detected	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	6:58 am	1.03	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	7:01 am	Not Detected	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	7:02 am	Not Detected	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	7:04 am	1.26	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	7:05 am	Not Detected	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	7:09 am	Not Detected	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	7:10 am	1.26	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	7:16 am	3.48	In Progress	
KU Kids Deanwood, LLC	1350 49th Street NE	7	Bathroom	Wednesday, 06-16-2021	7:17 am	1.05	In Progress	
Learning Leaf Childcare Center (4 SAMPLE records)								
Learning Leaf Childcare Center	2555 Pennsylvania Avenue NW	2	Kitchen	Thursday, 06-24-2021	6:27 am	Not Detected	In Progress	
Learning Leaf Childcare Center	2555 Pennsylvania Avenue NW	2	Kitchen	Thursday, 06-24-2021	6:27 am	Not Detected	In Progress	
Learning Leaf Childcare Center	2555 Pennsylvania Avenue NW	2	Kitchen	Thursday, 06-24-2021	6:28 am	Not Detected	In Progress	
Learning Leaf Childcare Center	2555 Pennsylvania Avenue NW	2	Kitchen	Thursday, 06-24-2021	6:29 am	Not Detected	In Progress	
Palisades Montessori Infant and Toddler Center (8 SAMPLE records)								
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Kitchenette	Friday, 06-25-2021	7:41 am	Not Detected	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Kitchenette	Friday, 06-25-2021	7:41 am	Not Detected	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Kitchenette	Friday, 06-25-2021	7:42 am	Not Detected	In Progress	
Palisades Montessori	5104 MacArthur	3	Kitchenette	Friday, 06-25-2021	7:43 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Infant and Toddler Center	Boulevard NW							
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Classroom	Friday, 06-25-2021	7:45 am	Not Detected	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Classroom	Friday, 06-25-2021	7:45 am	Not Detected	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Classroom	Friday, 06-25-2021	7:46 am	Not Detected	In Progress	
Palisades Montessori Infant and Toddler Center	5104 MacArthur Boulevard NW	3	Classroom	Friday, 06-25-2021	7:47 am	Not Detected	In Progress	
Sukarno Glory Childcare Development Center (8 SAMPLE records)								
Sukarno Glory Childcare Development Center	2323 Pennsylvania Avenue SE	7	Kitchen	Thursday, 06-10-2021	7:05 am	Not Detected	Filter Installed	12-16-2021
Sukarno Glory Childcare Development Center	2323 Pennsylvania Avenue SE	7	Kitchen	Thursday, 06-10-2021	7:05 am	Not Detected	Filter Installed	12-16-2021
Sukarno Glory Childcare Development Center	2323 Pennsylvania Avenue SE	7	Kitchen	Thursday, 06-10-2021	7:06 am	Not Detected	Filter Installed	12-16-2021
Sukarno Glory Childcare Development Center	2323 Pennsylvania Avenue SE	7	Kitchen	Thursday, 06-10-2021	7:07 am	Not Detected	Filter Installed	12-16-2021
Sukarno Glory Childcare Development Center	2323 Pennsylvania Avenue SE	7	Kitchen	Thursday, 06-10-2021	7:09 am	Not Detected	Filter Installed	12-16-2021
Sukarno Glory Childcare Development Center	2323 Pennsylvania Avenue SE	7	Kitchen	Thursday, 06-10-2021	7:09 am	Not Detected	Filter Installed	12-16-2021
Sukarno Glory Childcare Development Center	2323 Pennsylvania Avenue SE	7	Kitchen	Thursday, 06-10-2021	7:10 am	Not Detected	Filter Installed	12-16-2021
Sukarno Glory Childcare Development Center	2323 Pennsylvania Avenue SE	7	Kitchen	Thursday, 06-10-2021	7:11 am	Not Detected	Filter Installed	12-16-2021
UPO @ Ketcham Elementary School (10 SAMPLE records)								
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Kitchen	Thursday, 06-10-2021	7:40 am	Not Detected	Filter Installed	11-10-2022
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Kitchen	Thursday, 06-10-2021	7:40 am	Not Detected	Filter Installed	11-10-2022
UPO @ Ketcham	1919 15th Street SE	8	Kitchen	Thursday, 06-10-2021	7:41 am	Not Detected	Filter Installed	11-10-2022

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Elementary School								
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Kitchen	Thursday, 06-10-2021	7:42 am	Not Detected	Filter Installed	11-10-2022
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Classroom	Thursday, 06-10-2021	7:46 am	1.58	In Progress	
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Classroom	Thursday, 06-10-2021	7:47 am	Not Detected	In Progress	
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Classroom	Thursday, 06-10-2021	7:51 am	1.52	In Progress	
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Classroom	Thursday, 06-10-2021	7:52 am	Not Detected	In Progress	
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Classroom	Thursday, 06-10-2021	7:54 am	1.48	In Progress	
UPO @ Ketcham Elementary School	1919 15th Street SE	8	Classroom	Thursday, 06-10-2021	7:55 am	Not Detected	In Progress	
Woodbridge Day Care Center V (4 SAMPLE records)								
Woodbridge Day Care Center V	3302 18th Street NE	5	Kitchen	Tuesday, 06-15-2021	7:07 am	Not Detected	Filter Installed	12-13-2021
Woodbridge Day Care Center V	3302 18th Street NE	5	Kitchen	Tuesday, 06-15-2021	7:07 am	Not Detected	Filter Installed	12-13-2021
Woodbridge Day Care Center V	3302 18th Street NE	5	Kitchen	Tuesday, 06-15-2021	7:08 am	Not Detected	Filter Installed	12-13-2021
Woodbridge Day Care Center V	3302 18th Street NE	5	Kitchen	Tuesday, 06-15-2021	7:09 am	Not Detected	Filter Installed	12-13-2021