

Lead in Drinking Water Sampling Results Report - **AUGUST 2021**

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Bright Beginnings, Inc. (4 SAMPLE records)								
Bright Beginnings, Inc.	3418 4th Street SE	8	Kitchen	Friday, 08-06-2021	7:30 am	Not Detected	Filter Installed	12-15-2021
Bright Beginnings, Inc.	3418 4th Street SE	8	Kitchen	Friday, 08-06-2021	7:30 am	Not Detected	Filter Installed	12-15-2021
Bright Beginnings, Inc.	3418 4th Street SE	8	Kitchen	Friday, 08-06-2021	7:31 am	Not Detected	Filter Installed	12-15-2021
Bright Beginnings, Inc.	3418 4th Street SE	8	Kitchen	Friday, 08-06-2021	7:32 am	Not Detected	Filter Installed	12-15-2021
Bright Start Early Care Preschool II (10 SAMPLE records)								
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	7:22 am	Not Detected	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	7:22 am	Not Detected	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	7:23 am	Not Detected	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	7:24 am	Not Detected	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Bathroom	Wednesday, 08-18-2021	7:28 am	1.04	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Bathroom	Wednesday, 08-18-2021	7:28 am	Not Detected	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Bathroom	Wednesday, 08-18-2021	7:29 am	Not Detected	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Bathroom	Wednesday, 08-18-2021	7:30 am	Not Detected	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Classroom	Wednesday, 08-18-2021	7:33 am	Not Detected	In Progress	
Bright Start Early Care Preschool II	5524 Georgia Avenue NW	4	Classroom	Wednesday, 08-18-2021	7:34 am	Not Detected	In Progress	
Capital Kids DC (4 SAMPLE records)								
Capital Kids DC	1250 24th Street NW	2	Kitchen	Wednesday, 08-25-2021	7:33 am	Not Detected	In Progress	
Capital Kids DC	1250 24th Street NW	2	Kitchen	Wednesday, 08-25-2021	7:33 am	Not Detected	In Progress	
Capital Kids DC	1250 24th Street NW	2	Kitchen	Wednesday, 08-25-2021	7:34 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
DC	Street NW					Detected		
Capital Kids DC	1250 24th Street NW	2	Kitchen	Wednesday, 08-25-2021	7:35 am	Not Detected	In Progress	
Children Of The Future (4 SAMPLE records)								
Children Of The Future	1216 Saratoga Avenue NE	5	Kitchen	Friday, 08-13-2021	9:11 am	Not Detected	In Progress	
Children Of The Future	1216 Saratoga Avenue NE	5	Kitchen	Friday, 08-13-2021	9:11 am	Not Detected	In Progress	
Children Of The Future	1216 Saratoga Avenue NE	5	Kitchen	Friday, 08-13-2021	9:12 am	Not Detected	In Progress	
Children Of The Future	1216 Saratoga Avenue NE	5	Kitchen	Friday, 08-13-2021	9:13 am	Not Detected	In Progress	
DC Superior Court Child Care Center (12 SAMPLE records)								
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Lunch Room	Wednesday, 08-11-2021	7:40 am	Not Detected	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Lunch Room	Wednesday, 08-11-2021	7:40 am	Not Detected	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Lunch Room	Wednesday, 08-11-2021	7:41 am	5.56	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Lunch Room	Wednesday, 08-11-2021	7:42 am	Not Detected	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Classroom	Wednesday, 08-11-2021	7:46 am	Not Detected	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Classroom	Wednesday, 08-11-2021	7:46 am	1.96	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Classroom	Wednesday, 08-11-2021	7:47 am	2.61	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Classroom	Wednesday, 08-11-2021	7:48 am	Not Detected	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Classroom	Wednesday, 08-11-2021	7:51 am	Not Detected	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Classroom	Wednesday, 08-11-2021	7:51 am	Not Detected	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Classroom	Wednesday, 08-11-2021	7:52 am	1.26	Filter Installed	10-04-2021
DC Superior Court Child Care Center	500 Indiana Avenue NW	6	Classroom	Wednesday, 08-11-2021	7:53 am	Not Detected	Filter Installed	10-04-2021
Diplotots, Too (20 SAMPLE records)								
Diplotots, Too	600 19th	2	Bathroom	Wednesday, 08-04-2021	7:16 am	Not	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
	Street NW					Detected		
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:16 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:17 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:18 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:22 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:22 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:23 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:24 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:29 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:29 am	4.71	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:30 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:31 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:37 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:37 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:38 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:39 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:41 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:41 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:42 am	Not Detected	In Progress	
Diplotots, Too	600 19th Street NW	2	Bathroom	Wednesday, 08-04-2021	7:43 am	Not Detected	In Progress	
Emergent Preparatory Academy III (4 SAMPLE records)								
Emergent Preparatory Academy III	330 Rhode Island Avenue NE	5	Infant Room	Friday, 08-27-2021	7:22 am	Not Detected	Filter Installed	12-13-2021
Emergent Preparatory Academy III	330 Rhode Island Avenue NE	5	Infant Room	Friday, 08-27-2021	7:23 am	Not Detected	Filter Installed	12-13-2021
Emergent Preparatory Academy III	330 Rhode Island Avenue NE	5	Kitchen	Friday, 08-27-2021	7:25 am	Not Detected	Filter Installed	12-13-2021
Emergent Preparatory Academy III	330 Rhode Island Avenue NE	5	Kitchen	Friday, 08-27-2021	7:26 am	Not Detected	Filter Installed	12-13-2021

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Federal Home Loan Bank Board Small Savers CDC (4 SAMPLE records)								
Federal Home Loan Bank Board Small Savers CDC	1700 G Street NW	2	Kitchen	Thursday, 08-12-2021	7:45 am	Not Detected	In Progress	
Federal Home Loan Bank Board Small Savers CDC	1700 G Street NW	2	Kitchen	Thursday, 08-12-2021	7:45 am	Not Detected	In Progress	
Federal Home Loan Bank Board Small Savers CDC	1700 G Street NW	2	Kitchen	Thursday, 08-12-2021	7:46 am	Not Detected	In Progress	
Federal Home Loan Bank Board Small Savers CDC	1700 G Street NW	2	Kitchen	Thursday, 08-12-2021	7:47 am	Not Detected	In Progress	
Floricelda M. Avila De Alvarez (2 SAMPLE records)								
Floricelda M. Avila De Alvarez	1847 Mintwood Place NW	1	Kitchen	Wednesday, 08-25-2021	8:09 am	Not Detected	Filter Installed	05-27-2020
Floricelda M. Avila De Alvarez	1847 Mintwood Place NW	1	Kitchen	Wednesday, 08-25-2021	8:10 am	Not Detected	Filter Installed	05-27-2020
Growing Minds Together (4 SAMPLE records)								
Growing Minds Together	538 Madison Street NW	4	Kitchen	Friday, 08-27-2021	8:24 am	Not Detected	Filter Installed	03-11-2022
Growing Minds Together	538 Madison Street NW	4	Kitchen	Friday, 08-27-2021	8:24 am	Not Detected	Filter Installed	03-11-2022
Growing Minds Together	538 Madison Street NW	4	Kitchen	Friday, 08-27-2021	8:25 am	Not Detected	Filter Installed	03-11-2022
Growing Minds Together	538 Madison Street NW	4	Kitchen	Friday, 08-27-2021	8:26 am	Not Detected	Filter Installed	03-11-2022
Home Away From Home Too Child Development Center Inc. (4 SAMPLE records)								
Home Away From Home Too Child Development Center Inc.	4119 4th Street SE	8	Kitchen	Thursday, 08-12-2021	6:15 am	23.3	In Progress	
Home Away From Home Too Child Development Center Inc.	4119 4th Street SE	8	Kitchen	Thursday, 08-12-2021	6:15 am	4.59	In Progress	
Home Away From Home Too Child Development Center Inc.	4119 4th Street SE	8	Kitchen	Thursday, 08-12-2021	6:16 am	Not Detected	In Progress	
Home Away From Home Too Child Development Center Inc.	4119 4th Street SE	8	Kitchen	Thursday, 08-12-2021	6:17 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Israel Baptist Church CDC (4 SAMPLE records)								
Israel Baptist Church CDC	1251 Saratoga Avenue NE	5	Kitchen	Tuesday, 08-24-2021	6:35 am	Not Detected	Filter Installed	06-03-2022
Israel Baptist Church CDC	1251 Saratoga Avenue NE	5	Kitchen	Tuesday, 08-24-2021	6:35 am	Not Detected	Filter Installed	06-03-2022
Israel Baptist Church CDC	1251 Saratoga Avenue NE	5	Kitchen	Tuesday, 08-24-2021	6:36 am	Not Detected	Filter Installed	06-03-2022
Israel Baptist Church CDC	1251 Saratoga Avenue NE	5	Kitchen	Tuesday, 08-24-2021	6:37 am	Not Detected	Filter Installed	06-03-2022
KD's Klubhouse (12 SAMPLE records)								
KD's Klubhouse	700 Southern Avenue SE	8	Kitchen	Wednesday, 08-04-2021	7:05 am	Not Detected	Filter Installed	12-15-2021
KD's Klubhouse	700 Southern Avenue SE	8	Kitchen	Wednesday, 08-04-2021	7:05 am	Not Detected	Filter Installed	12-15-2021
KD's Klubhouse	700 Southern Avenue SE	8	Kitchen	Wednesday, 08-04-2021	7:06 am	Not Detected	Filter Installed	12-15-2021
KD's Klubhouse	700 Southern Avenue SE	8	Kitchen	Wednesday, 08-04-2021	7:07 am	Not Detected	Filter Installed	12-15-2021
KD's Klubhouse	700 Southern Avenue SE	8	Bathroom	Wednesday, 08-04-2021	7:18 am	Not Detected	In Progress	
KD's Klubhouse	700 Southern Avenue SE	8	Bathroom	Wednesday, 08-04-2021	7:18 am	Not Detected	In Progress	
KD's Klubhouse	700 Southern Avenue SE	8	Bathroom	Wednesday, 08-04-2021	7:19 am	Not Detected	In Progress	
KD's Klubhouse	700 Southern Avenue SE	8	Bathroom	Wednesday, 08-04-2021	7:20 am	Not Detected	In Progress	
KD's Klubhouse	700 Southern Avenue SE	8	Bathroom	Wednesday, 08-04-2021	7:27 am	Not Detected	Filter Installed	09-29-2022
KD's Klubhouse	700 Southern Avenue SE	8	Bathroom	Wednesday, 08-04-2021	7:27 am	Not Detected	Filter Installed	09-29-2022
KD's Klubhouse	700 Southern Avenue SE	8	Bathroom	Wednesday, 08-04-2021	7:28 am	Not Detected	Filter Installed	09-29-2022
KD's Klubhouse	700 Southern Avenue SE	8	Bathroom	Wednesday, 08-04-2021	7:29 am	Not Detected	Filter Installed	09-29-2022
Martha's Table Maycroft Early Learning Center (28 SAMPLE records)								
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	6:54 am	2.14	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia	1	Classroom	Friday, 08-27-2021	6:54 am	3.78	Filter Installed	12-09-2021

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Learning Center	Road NW							
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	6:55 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	6:56 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	6:58 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	6:59 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:03 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:03 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:04 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:05 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:07 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:08 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:13 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:13 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:14 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:15 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:17 am	Not Detected	In Progress	
Martha's Table Maycroft Early Learning Center	1474 Columbia	1	Classroom	Friday, 08-27-2021	7:18 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Learning Center	Road NW							
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:22 am	Not Detected	In Progress	
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:22 am	Not Detected	In Progress	
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:23 am	Not Detected	In Progress	
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:24 am	Not Detected	In Progress	
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:26 am	Not Detected	In Progress	
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Classroom	Friday, 08-27-2021	7:27 am	Not Detected	In Progress	
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Kitchenette	Friday, 08-27-2021	7:30 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Kitchenette	Friday, 08-27-2021	7:30 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Kitchenette	Friday, 08-27-2021	7:31 am	Not Detected	Filter Installed	12-09-2021
Martha's Table Maycroft Early Learning Center	1474 Columbia Road NW	1	Kitchenette	Friday, 08-27-2021	7:32 am	Not Detected	Filter Installed	12-09-2021
Montessori School Of Chevy Chase (4 SAMPLE records)								
Montessori School Of Chevy Chase	5312 Connecticut Avenue NW	3	Kitchen	Thursday, 08-05-2021	7:34 am	4.27	Filter Installed	10-05-2021
Montessori School Of Chevy Chase	5312 Connecticut Avenue NW	3	Kitchen	Thursday, 08-05-2021	7:34 am	2.19	Filter Installed	10-05-2021
Montessori School Of Chevy Chase	5312 Connecticut Avenue NW	3	Kitchen	Thursday, 08-05-2021	7:35 am	Not Detected	Filter Installed	10-05-2021
Montessori School Of Chevy Chase	5312 Connecticut Avenue NW	3	Kitchen	Thursday, 08-05-2021	7:36 am	9.47	Filter Installed	10-05-2021
Narbear Child Development Home Daycare (10 SAMPLE records)								
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:03 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:03 am	1.02	In Progress	
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:04 am	Not Detected	In Progress	
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:05 am	1.11	In Progress	
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:11 am	Not Detected	In Progress	
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:11 am	Not Detected	In Progress	
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:12 am	Not Detected	In Progress	
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:13 am	Not Detected	In Progress	
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:14 am	Not Detected	In Progress	
Narbear Child Development Home Daycare	4725 9th Street NW	4	Kitchen	Friday, 08-27-2021	6:15 am	Not Detected	In Progress	
National Presbyterian Child Care Center (6 SAMPLE records)								
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Classroom	Thursday, 08-05-2021	6:43 am	Not Detected	Filter Installed	11-16-2022
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Classroom	Thursday, 08-05-2021	6:44 am	Not Detected	Filter Installed	11-16-2022
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Classroom	Thursday, 08-05-2021	6:45 am	Not Detected	In Progress	
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Classroom	Thursday, 08-05-2021	6:46 am	Not Detected	In Progress	
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Bathroom	Thursday, 08-05-2021	6:49 am	Not Detected	Filter Installed	11-16-2022
National Presbyterian Child Care Center	4124 Van Ness Street NW	3	Bathroom	Thursday, 08-05-2021	6:50 am	Not Detected	Filter Installed	11-16-2022
Prep Enrichment Center (2 SAMPLE records)								
Prep Enrichment Center	1604 Park Road NW	4	Kitchen	Tuesday, 08-24-2021	7:42 am	Not Detected	In Progress	
Prep Enrichment Center	1604 Park Road NW	4	Kitchen	Tuesday, 08-24-2021	7:43 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Quickie Becky Child Care Dev (8 SAMPLE records)								
Quickie Becky Child Care Dev	6135 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	6:36 am	1.36	Filter Installed	10-05-2021
Quickie Becky Child Care Dev	6135 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	6:36 am	10.9	Filter Installed	10-05-2021
Quickie Becky Child Care Dev	6135 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	6:37 am	Not Detected	Filter Installed	10-05-2021
Quickie Becky Child Care Dev	6135 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	6:38 am	Not Detected	Filter Installed	10-05-2021
Quickie Becky Child Care Dev	6135 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	6:46 am	Not Detected	In Progress	
Quickie Becky Child Care Dev	6135 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	6:46 am	Not Detected	In Progress	
Quickie Becky Child Care Dev	6135 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	6:47 am	Not Detected	In Progress	
Quickie Becky Child Care Dev	6135 Georgia Avenue NW	4	Kitchenette	Wednesday, 08-18-2021	6:48 am	Not Detected	In Progress	
Rising Stars Early Learning Center (10 SAMPLE records)								
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Kitchen	Thursday, 08-26-2021	6:45 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Kitchen	Thursday, 08-26-2021	6:45 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Kitchen	Thursday, 08-26-2021	6:46 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Kitchen	Thursday, 08-26-2021	6:47 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Hallway	Thursday, 08-26-2021	6:49 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Hallway	Thursday, 08-26-2021	6:50 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Classroom	Thursday, 08-26-2021	6:56 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Classroom	Thursday, 08-26-2021	6:56 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Classroom	Thursday, 08-26-2021	6:57 am	Not Detected	In Progress	
Rising Stars Early Learning Center	4212 East Capitol Street NE	7	Classroom	Thursday, 08-26-2021	6:58 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
The Montessori School of Washington (6 SAMPLE records)								
The Montessori School of Washington	4380 MacArthur Boulevard NW	3	Kitchenette	Friday, 08-13-2021	7:38 am	1.09	In Progress	
The Montessori School of Washington	4380 MacArthur Boulevard NW	3	Kitchenette	Friday, 08-13-2021	7:39 am	Not Detected	In Progress	
The Montessori School of Washington	4380 MacArthur Boulevard NW	3	Kitchenette	Friday, 08-13-2021	7:42 am	Not Detected	In Progress	
The Montessori School of Washington	4380 MacArthur Boulevard NW	3	Kitchenette	Friday, 08-13-2021	7:42 am	Not Detected	In Progress	
The Montessori School of Washington	4380 MacArthur Boulevard NW	3	Kitchenette	Friday, 08-13-2021	7:43 am	Not Detected	In Progress	
The Montessori School of Washington	4380 MacArthur Boulevard NW	3	Kitchenette	Friday, 08-13-2021	7:44 am	Not Detected	In Progress	
Two Birds Tenleytown (22 SAMPLE records)								
Two Birds Tenleytown	4001 Bradywine Street NW	3	Kitchen	Wednesday, 08-11-2021	6:13 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Kitchen	Wednesday, 08-11-2021	6:13 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Kitchen	Wednesday, 08-11-2021	6:14 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Kitchen	Wednesday, 08-11-2021	6:15 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Open Area	Wednesday, 08-11-2021	6:18 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Open Area	Wednesday, 08-11-2021	6:19 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:26 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:26 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:27 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:28 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:30 am	Not Detected	In Progress	

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Energy and Environment

Facility Name	Physical Address	DC Ward	Room Type	Sample Collection Date	Sample Collection Time	Result (ppb)	Remediation	Remediation Completion Date
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:30 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:31 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:32 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:36 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:36 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:37 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:38 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:40 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:40 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:41 am	Not Detected	In Progress	
Two Birds Tenleytown	4001 Bradywine Street NW	3	Bathroom	Wednesday, 08-11-2021	6:42 am	Not Detected	In Progress	
YMCA At Avalon (2 SAMPLE records)								
YMCA At Avalon	820 Southern Avenue SE	8	Hallway	Wednesday, 08-04-2021	8:20 am	Not Detected	In Progress	
YMCA At Avalon	820 Southern Avenue SE	8	Hallway	Wednesday, 08-04-2021	8:21 am	Not Detected	In Progress	